


TOTALIZER COUNTER(SQX-100 RS485 통신)SETTING MANUAL

1. COMMUNICATION SPECIFICATION

- 1.1 COMMUNICATION TYPE : RS485
- 1.2 PROTOCOL : MODBUS RTU
- 1.3 DATA LENGTH : 8 BIT
- 1.4 STOP BIT : 1 BIT
- 1.5 PARITY : NONE
- 1.6 DATA TRANSMISSION/BAUD RATE : 9600, 19200
- 1.7 RECOMMENDED DISTANCE(WITH MAXIMUM) : 4000ft/1200m
- 1.8 MAXIMUM NUMBER OF CONTACT UNIT : 35 UNITS
- 1.9 DATA REGISTER : INPUT (READ) REGISTER (30000)
HOLD (READ, WRITE) REGISTER (40000)
- 1.10 COUNTER ADDRESS : 00001, 00002번지


COUNTER (6 DIGIT)



<예>
HOLD REGISTER 일때
40001번지 (HI WORD)
40002번지 (LOW WORD)

2. SERIAL COMMUNICATION COUNTER DIAGRAMS

* RS 485 통신 INPUT결선



- * RS485 통신 Shield Cable 결선시 Master 쪽 Shield Cable의 Ground를 잡아 주십시오.
- * 소숫점은 COUNTER' 전면 S/W와 PROGRAM상 모두 지정이 가능하며 PROGRAM상의 DATA를 우선시 합니다.

